# COMPENSATOR 0 - 10VDC FOR BOILERS OR MIXING VALVES

### E13-PCOM1

This simple compensator can be used to adjust boiler flow temperature in relation to changes in outside temperature.

Valve: A 0-10VDC mixing valve can be modulated according to variations in outside temperature

Boiler(s): Alternatively, the 0-10VDC signal can be wired into a relay ie. E4RM to switch a boiler or several boilers in sequence. The time delay on the relay can prevent nuisance cycling.



The compensator must be used with an outside sensor and a flow sensor.


The display can be toggled to show flow temperature, outside temperature and calculated flow set-point by pressing the up button. The display remains on for approx 5 mins after any adjustments are made and then turns off. It is activated again by pressing the SET button.


Frost protection & high limit devices must be installed in the heating system.

Power Consumption: 2VA

Туре	Flow High at Outside Temp 0 C C	Flow Low at Outside Temp 20 C C	Prop Band C	Night Setback C	Integral Time Adj	Supply ± 15%	Output	Mounting	Protection
E13-PCOM1	25 to 90 Preset 80	20 to 60 Preset 20	0 to 40 Preset 8	0 to 30 Preset 20	0-500s	24VAC/DC	0-10vdc	Din Rail	IP00
ACCESSORIE	S E10-X	Outside Sensor 80 dia x 55							
	E10-I	Immersion Sensor 80 dia x 55 Probe Length 120mm x 6mm OD See pocket below -							IP65
SEE SEPARAT DATA SHEET		Strap-On Sensor with strap for up to 6" dia. Pipe. 2m cable Approx 80 dia x 55mm							IP65
	EE-2B	Brass Pocket 1/2" BSP x 120mm long x 6,2mm ID							
	E10-P4	Adjusts Calculated Flow Set Point by +/- 4 C. Front panel mtg 48mm x 48mm							
	EE-M2T	Wall mounting enclosure for E13 125H x 125W x 75D							IP65

WIRING:





## SETTINGS:

Pressing the ▲ ▼ buttons allows adjustment during any of the following stages.

- 1. Press SET Button = Set Flow High LD1 Lights Adjust to the Flow High value desired when the outside temperature is 0 C
- 2. Press SET Button = Set Flow Low LD2 Lights Adjust to the Flow Low value desired when the outside temperature is 20 C
- 3. Press SET Button = Set Prop Band LD3 Lights Adjust Prop Band
- Press SET Button = Night Setback LD5 Lights Adjust Night Setback. Enabled upon contact closure on terminals N1 D0
   This will reduce the calculated flow set point by X C during the night
- 5. Press SET Button = Integral x10s LD6 Lights Adjust Integral Time between 0 and 500 seconds

Pressing the SET Button again restarts the sequence. The unit returns to normal operation if left untouched for 15 seconds.


\* During normal operation - by pressing the up button, the display can be toggled to show flow temperature (LD7 Lights), outside temperature (LD8 Lights) or calculated flow set-point (Both LD7 and LD8 Light).

### EXAMPLES:

If when outside temperature is 0 C the compensated flow temperature required is 80 C, then set the Flow High to 80 C. If when the outside temperature is 20 C the compensated flow temperature required is 20 C, then set the Flow Low to 20 C.

According to these settings the calculated flow set point will move along the slope
- ie. at 10 C outside temperature, the set point will be 50 C.
Therefore when the flow sensor reaches 50 C the output will be 0vdc.

As the flow falls below 50 C the output will increase towards 10vdc across the prop band. By using the E10-P4 the calculated flow set point can be adjusted up or down by up to 4 degrees.



### INSTALLATION:

Terminals 0.5-2.5mm Sensor cable size 7/0.2mm Keep away from power cables/units which may cause interference.

Max length 100m. Screened cable is highly recommended. The screen should be earthed at the controller 0V terminal only.