Emergency Stop Button Key Lock

Features

- Push to latch
- Key to unlock



Specification

Switch rating:

4A @ 15 to 415Vac 0.5A @ 13 to 110Vdc

Dimensions 65 x 65 x 90mm

Country of origin UK

Product Codes

EP-KL

Key reset emergency stop button



Date Of Issue: 12/10/2010 © 2010 Sontay Limited. All rights reserved.

Technical Overview

The EP-KL emergency stop button is intended for manual close down of gas systems in the event of fire or other emergency. Usually located at exits to gas plant rooms. They are 'push' to activate a latching switch, which is released by a 'key'.

Units are fitted with 1 contact switch.

Installation

- 1. The EP-SW range should only be installed by a competent, suitably trained technician, experienced in installation with hazardous voltages. (>50Vac & <1000Vac or >75Vdc & 1500Vdc)
- 2. Ensure that all power is disconnected before carrying out any work on the EP-KL.
- 3. Separate the switch base and top.
- 4. Using the base as a template, fix to the surface with suitable screws.
- 5. Knock out hole at the top or bottom of the base to allow cable entry.
- 6. Terminate the cores leaving some slack inside the unit.
- 7. Replace the top unit.

Connections

Connections are made via the contact block inside the hous-

