

## Emergency Stop Buttons

### Features



- Push to latch
- Range of actions to unlatch

### Specification

Switch rating	6A @ 240Vac
Dimensions:	
EP-SW10	79 x 72 x 42mm
EP-SW11	79 x 72 x 75mm
Installation category	IEC 664 Category II
Pollution degree	IEC 664 Degree 1
Country of origin	UK

### Product Codes

#### EP-SW10

Push reset emergency stop button

#### EP-SW11

Twist reset emergency stop button

## Technical Overview

The EP-SW range of emergency stop buttons are for manual close down of gas systems in the event of fire or other emergency. Usually located at exits to gas plant rooms. All units are 'push' to activate a latching switch, which is released by either a recessed 'push', or 'twist'. Available in bright yellow with red button. The units are fitted with 1 contact switch.

## Installation

1. The EP-SW range should only be installed by a competent, suitably trained technician, experienced in installation with hazardous voltages. ( $>50\text{Vac}$  &  $<1000\text{Vac}$  or  $>75\text{Vdc}$  &  $1500\text{Vdc}$ )
2. Ensure that all power is disconnected before carrying out any work on the EP-SW range.
3. Separate the switch base and top.
4. Using the base as a template, fix to the surface with suitable screws.
5. Knock out hole at the top or bottom of the base to allow cable entry.
6. Terminate the cores leaving some slack inside the unit.
7. Replace the top unit.

## Connections

Connections are made via the contact block inside the housing

